


# Grid Integration & Modeling Distributed & Variable Renewable Energy Resources



IPU GRID SCHOOL 2024

JUNE 12, 2024

INSTITUTE OF PUBLIC UTILITIES

THOMAS VESELKA


ARGONNE NATIONAL LABORATORY

DO NOT CITE OR DISTRIBUTE WITHOUT  
PERMISSION

MICHIGAN STATE UNIVERSITY

# Power Grid Dispatch and Production Costs


*In the absence of transmission congestion and transmission losses, low-cost generators are typically deployed first, and expensive generators are used last*



***The marginal cost to serve load is the same throughout the system***




In a System without Transmission Congestion and Losses, Marginal System Costs Can Be Computed with Supply and Demand Curves



**Example: Loads on all Lines Are less than the Total Transfer Capability of each Line – Unconstrained Dispatch**

# Dispatch with Demands of 250 MW *with* Congestion (Radial Network)



## Dispatch with congestion

**Total Production Cost**

$100 \text{ MW} \times 10 \text{ $/MWh} = \$1,000$
$75 \text{ MW} \times 30 \text{ $/MWh} = \$2,250$
$75 \text{ MW} \times 75 \text{ $/MWh} = \$5,625$
<b>Total = \$8,875</b>


Cost Increase = \$1,125

## Dispatch without congestion

**Total Production Cost**





$100 \text{ MW} \times 10 \text{ $/MWh} = \$1,000$
$100 \text{ MW} \times 30 \text{ $/MWh} = \$3,000$
$50 \text{ MW} \times 75 \text{ $/MWh} = \$3,750$
<b>Total = \$7,750</b>

# Units Are Dispatched Out of Merit Order Because of Transmission Congestion



**Transmission congestion alters the unit dispatch and increase grid production cost**

A Balancing Authority (BA) Operator Maintains Load and Generation Balance within an Area and Supports Interconnection Frequency in Real-time




***Tie-line flows are scheduled to take advantage of economic power transfers among BAs***

# Production Fluctuation from Variable Renewable Energy (VRE) Resources

*Primarily Wind and Solar Photovoltaic (PV) but  
also Run-of-river Hydropower*



# A Major Challenge for Integrating VRE into the Grid Is to Respond to Rapid Fluctuations Production Levels under Uncertain (Forecasting Error)




**Other generating resources or loads need to adjust quickly**

# Arizona Public Service Solar Production

## Three Days of APS' Historical Solar Energy Production January 2013


Rated Capacity of 110 MW Excluding Solana

— 1/10/2013 — 1/28/2013 — 2/4/2013



The graph is from an APS presentation given to the Arizona Corporation Commission on 9/11/2014


# Historical Photovoltaic Output Ensemble Data for 1 Year



Source: <http://www.icrepq.com/ICREPQ'09/abstracts/520-ramon-abstract.pdf>

# Run-of-River Hydropower “the Other VRE”


*July Flow Rate (cfs) Profiles at Snake River Gauge, 2011-2015*



**Wind and solar resources may also need to occasionally “spill” energy** 12

# Run-of-River (ROR) Hydropower “the other VRE”

*July Power Production (W) Profiles (Snake River ROR Plant), 2011-2015*




# Net Loads


*Load - VRE Resource Generation*



# Wind and Solar Production Tend to, but not Always, Reduce both Marginal and Total Production Costs




Dispatchable Units Serve a Load Profile that Typically, but not always, Has Greater Fluctuations Relative to the Case where there Is no Wind





# Arizona Public Service Solar Production



The graph is from an APS presentation given to the Arizona Corporation Commission on 9/11/2014

# CAISO Renewable Energy Generation Profile


March 1, 2021



# CAISO Net Demand Profile, March 1, 2021

## Operating Challenges

- *Unit commitments (min/max gen)*
- *Midday over supply (slow-start unit commitments/DA forecast error)*
- *Fast start unit-commitments (responding to HA forecast error)*
- *Large daily range*
- *Fast ramping*




Thermal Generation Resources  
Ability to Respond to Temporal  
Changes in Net Load

*Operational Flexibility*



# Changes in Net Load Are Mainly Resolved by Adjusting Thermal Unit and Hydroelectric Power Plant Outputs

*The greater the operational flexibility of dispatchable units, the more variability the grid can accommodate*





# CAISO Generation Profile

## March 1, 2021






# Net Load Following Is Restricted by the Unit's Output Range and Ramp Rate Limits

## Range and Ramp Rate Limits




# Some Technologies Are Able to Come On-line Quickly to Respond to Rapid Load Changes while Others Are Less Flexible






# Ideally, Units Are Dispatched Based on Production Cost


No Operating Constraints & No Congestion



# A Steam Plant Does not Have the Flexibility to Operate at a Low Level



# Cost Typically Decrease at Different Levels During a Day




PV Array  
Inverters  
1-4

PV Array  
Inverters  
5-8




PV Array  
Inverters 9-  
12

*Lanai 1.5 MW Hawaii's  
largest solar farm in  
service as of Dec 2008*

March 16-25 2008 Frequency / KWP MW - One Minute Intervals



# Variable Resources Displace Fossil Fuels and Reduces Pollution




**Plans for  
future  
operations**

# Scheduling Unit Commitments/Generation and System Real Time Dispatch

**Actual  
operation  
of the  
system**

# Typical Scheduling and Dispatch Sequence

*Schedulers and Operators React to Changing Projections and RT Grid Conditions*




## Unit Commitments



- Based on load profiles, unit constraints, and forecast error, decisions are made regarding when each individual unit should be turned on (commit) and when to turn it off
- It is important to not only have enough capacity on-line to always meet load, but have sufficient ramping capabilities and operational flexibility to meet fluctuating grid demand
- For example, all units may not be needed during low load periods, and therefore some are turned off, but as load grows, resources must have the operational flexibility to match net load growth
- To minimize cost, cheap units are typically utilized first, but these low production cost units typically are the ones that cannot be quickly turned on quickly and may be expensive to start
- Frequent unit cycling typically results in higher O&M expenses, refurbishment costs and longer down-times




# Unit Operational Status (on/off) Is Primarily Based on Variable Production Costs and on Start-up/Shut-Down Costs




# CAISO Hourly Resource Sufficiency Evaluation

- CAISO resource checks
  - Balanced *Base Schedules*
  - Sufficient flexibility ramping capacity
  - Unresolved transmission congestion





**Resource Sufficiency Reduces a BA from “Leaning” on other EIM Entities**

**The Resource Plan is “Set in Stone” by the CAISO 40-minutes prior to the start of the operating hour and is the benchmark for energy deviation calculations**



# Longer-Term (Hourly) Movements

## Hourly Wind Ramping Events in the WALM BA




# Locational Marginal Prices (LMPs) In Non-Radial Networks

# Locational Marginal Price Components

## Supply components:

1. Marginal cost to purchase electricity
2. Cost of transmission congestion
3. Losses

*Marginal loss is often significantly higher than the average*




## Load:

1. Payment or incentive to a consumer to reduce demand

- LMP is a methodology that determines the optimal unit dispatch
- It simultaneously computes marginal energy costs at all locations (buses)
- It also computes the cost of transmission congestion in the power grid


**Bids are not required to reflect production costs, but LMPs may be adjusted in the market mitigation process**

# LMPs in a Simple Non-Radial Grid (Capacity & Costs)




*PC = Production Cost (\$/MWh)*  
*Cap. = Capacity (MW)*

# LMPs in a Simple Non-Radial Grid (PTDF T1 to L1)




# Single Source & Single Sink - Simple Non-Radial Grid




PC = Production Cost (\$/MWh)  
 Cap. = Capacity (MW)



# Single Source & Single Sink - Proportionality (350 MW Load)




# The Power Flow Limit on the T1-L1 Transmission Line Is Reached When T1 Output and Demand Is 362.5 MW




# Loads > 362.5 MW Will Require T2 To Be Dispatch (PTDF T2 to L1)

**Source: T2**  
**Sink: L1**




PC = Production Cost (\$/MWh)  
Cap. = Capacity (MW)


# When T2 Generates, T1 Reduces Generation below 362.5 MW to Avoid Line Overload -- Superposition (400 MW Load)



# The Value of VRE Production In a Congested Grid Can be Calculated by Serving the Load with A VRE and then Recalculating Production Costs



# The ISO Relieves Congestion by Opening the Congested Line



PC = Production Cost (\$/MWh)  
 Cap. = Capacity (MW)





# Locational Marginal Prices

Southwest Power Pool Real-time LMPs

## Legend

- ★ Hub
- ◆ Interface
- M2M Constraints



Tells us how much it costs the entire power grid to serve 1 MWh of load at a specific point

## Computed for the

- Day-ahead market
- Hour-ahead market
- 15-minute scheduling
- Real-time market

LMPs change over time, differ by time horizon and by location

# Hourly Energy Imbalances



# Balancing Authority (BA) and Energy Imbalances (EI)



EI Is Caused by the Difference between Scheduled and Actual levels

# Resources Are Needed to Respond to Error

## **Flexibility Reserves**

### ***Flex/Regulation***



- Short-term forecast errors
- Respond to changes faster than re-dispatch period
- Automatic generation control (AGC)

### ***Spin/Spinning***

- Longer term forecast errors
- Larger, slower, less frequent variations
- AGC not required
- 10-minute response
- Synchronized to the grid

### ***Non-spinning/Supplemental***

- Large, infrequent, slow moving events such as ramp forecast error
- 30-minute response



# Forecasts Are not Perfect in the Short-Term and less Accurate in the Long-Term

## ■ Error depends on several factors


- Prediction horizon
- Time of the year
- Capacity of resources
- Model inputs
- Model type
- Terrain complexity
- Spatial smoothing effect

*For example, wind power output is proportional to the wind speed cubed*

**Error in meteorological forecasts**


**Conversion process error**

**Errors in SCADA information and resource operation**




# An *energy imbalance* (EI) is the difference between scheduled and actual levels

- Applies to generation & loads
- Is a function of temporal scheduling granularity & dispatch interval
- Usually computed at the entity level




# CAISO Projected Load for Scheduling and Actual Load - March 1, 2020

Unit commitment schedules are typically based on these projections





# Generator EI Example:

## *Wind Turbine EI Caused by Forecast Error*



# Wind EI May Be a Significant Contribution to Net EI for a Specific Entity (wind owner) within a BA


BA Entity Hourly Total EI (MW)



Hourly Wind EI (MW)


# HA Forecast Error

*Forecast Error Example Is Based on Persistence Forecasting*






# Flexible Reserve Requirements Are Sometimes Based on the Current Variable Resource Generation Level



*Persistence Forecast Error Is Related to the Characteristics of the Wind Power Curve*

# Wind Plant Characterization



WIND SPEED (M/S)	POWER (KW)
0	0
3	21.9
4	75.1
5	155.8
6	274.3
7	439.3
8	668
9	932.1
10	1215.4
11	1418.2
12	1473.7
13	1496.5
14	1500.0
15	1500.0
16	1500.0
17	1500.0
18	1500.0
19	1500.0
20	1500.0
21	1500.0
22	1500.0


**CUT-IN WIND SPEED: 3.0 M/S**  
**CUT-OUT WIND SPEED: 22 M/S**

Air Density      Rotor Area      Performance Coefficient      Wind Speed


$$WindPower = \frac{1}{2} \rho A C_P V_{\infty}^3$$

**POWER OUTPUT IS REDUCED DUE TO GENERATOR LOSSES (20% - 50%) AND GEAR BOX LOSSES (~5%)**


# Flexible Reserve Requirements Is Based the Current Variable Resource Generation Level - *Low Generation*




# Flexible Reserve Requirements Is Based the Current Variable Resource Generation Level - *Medium Generation*



# Flexible Reserve Requirements Is Based the Current Variable Resource Generation Level - *High Generation*




# Flexible Reserve Requirements Affect the Operational Range of a Power Plant



# Instantaneous Energy Imbalances

# Area Control Error (ACE) Is a Measure of System Error in Balancing Area Interchange and Time Error



*Actual Versus Scheduled Net Interchanges (MW) Over BA Tie-Lines*



*Actual Versus Target Frequency (Hz)*

*Time Error (seconds)*

$$ACE = (T_a - T_s) - 10B_f (F_a - F_s) + \frac{\text{Fast (+) or Slow (-) clock}}{B_t} T_e$$


Area Bias per 0.1 Hz (MW/Hz)

**Units on Automatic Generation Control (AGC)**






# Load EI Occurs on an Instantaneous Basis



Load EI+: Actual load less than scheduled load

Load EI-: Actual load than scheduled load

EI Is either Positive (EI+: Energy Long) or Negative (EI-: Energy Short)





In addition to Load EI and Gen EI , EI is also caused by

Inadvertent flows:

EI+: higher than scheduled net inflow


EI-: Less than scheduled load

EI Has Random Properties both at the Hourly and 5-minute Time Steps




# Regulation Up and Down Services Intra-Base Unit Time Assumptions

**Unit on Automatic  
Generation Control (AGC)**




Traditionally, Operators Resolve EI Using Only Those Resources that Reside within its BA

BA Hourly Average EI (MW) During 1 Month



# Wind Power Influences Electricity Prices


Midwest ISO Wind Power and Iowa\* LMPs, May 11-17, 2009:



# Economic and Financial Cost of Providing Ancillary Services



# Ancillary Services (AS) Incurs Grid Economic Costs

*Commit More and Higher Cost Units*






# As a Result of Grid VRE Some Units Will Operate at a Different Efficiency Point



# Financial Implications for Generation Owner/Operators



*Ancillary Service Markets Provide Incentives to Provide These Services*



**Lost Opportunity (Cost) to Sell Higher Levels in the Energy Market**



**Reduced Operating Flexibility**

**Lower Efficiency (e.g., need to burn more fuel)**



Load	Partial Load Penalty (%)			
	Coal (ST)	Gas (CC)	Gas (CT)	Oil (CT)
25 %	34.19	44.84	64.97	113.46
50 %	9.06	13.20	17.97	26.82
75 %	2.24	3.82	4.76	5.27
100 %	0.00	0.00	0.00	0.00


# Reliability Increases as More Reserves Are Added but Higher Reliability Is Increasingly More Expensive



# VRE Technology Solutions



# Clouds Can Produce Rapid Changes in Incoming Solar Energy

## *PV Variability in the La Ola PV System*




**Irradiance and PV system ac output (typical partly cloudy day in July)**

# Jan 20<sup>th</sup> 2021 CAISO Curtailments




# Cumulative Hourly CAISO Wind and Solar Curtailment for the Month of January 2021

## Curtailed MWh YTD by Hour - 1/31/2021



**During Hours of Relatively Low VRE Production, Curtailments Are not Needed**

***Without curtailments the bottom of the trough would be deeper and the ramping would be steeper***




# Curtailments Increase as Solar Contributions to the Supply Mix Grows

Wind and solar curtailment totals by month

View ▾

Download ▾




**Solar Contribution Increased from about 11% to 14.2% between 2018 to 2019**



# Wind Technology Improvements Are Also Alleviating Some Problems Associated with Integrating Wind Energy into the Grid


*Example: The Danish Horns Rev Wind Farm Is Providing Regulation (Frequency Response) and Balancing Response*



Source: Smith et al., IEEE Power and Energy Magazine, Vol. 7. No.2, 2009.

# Actual Results from Solar Plant Ramping Test


*Output Closely Follows a Time Series Set Points*



# Actual Results from Solar Plant Regulation Test


## *Output Closely Follows 4-second Regulation Signals*

Regulation Up/Down Test — Sunrise (8/24/2016)



# Actual Results from Solar Plant Regulation Test



*Solar Regulation Accuracy Outperformed other Technologies*




Blue bars taken from the ISO's informational submittal to FERC on the performance of resources providing regulation services between January 1, 2015 and March 31, 2016

# CAISO Battery Operation- Jan 20, 2021

**Battery Storage Capacity**  
**2019:** 250 MW  
**2020:** 434 MW  
**2021:** 2,674 MW  
**2022:** 4,316 MW (projection)




Smooth Out the Net Loads




# Pumped Storage Plants (PSH) Provide a Variety of Benefits

- **Load shifting (energy arbitrage)**
  - Increases efficiency of system operation:
    - Increasing the generation of base load units
    - Reduces the operation of expensive units
- **Contingency reserve (spinning and non-spinning)**
  - Provides large amount of quick contingency reserve (e.g., for the outages of large nuclear and coal units)
- **Regulation reserve**
  - Helps maintain system frequency at a narrow band around nominal system frequency by balancing supply and demand
- **Load following**
  - Provides a quick-ramping capacity
- **Energy imbalance reduction**
  - Compensates the variability of wind and solar power




- ❑ Variable speed pumps provide flexibility in pump mode
- ❑ Traditional pumps are either on or off

# Pumped Storage Plants Can Be Used Fill Net Load Valleys and Shaves Peak Net Loads



**React to Sudden Changes in Variable Resource Production**



**Fill Load Valley (Consume) to Utilize Low Cost Production and Avoid Expensive Shutdown Costs**

# In Some Situations, Hydropower Plants Can Help Alleviate Variable Resource Integration Challenges

- Very flexible operation
  - Change operations quickly
  - Large range of operations
  - Good resource for ancillary services
- No fuel required
  - Very low production costs
  - Zero air emissions except for GHG
- High fixed costs
  - Expensive to build
  - Maintain dam, reservoir, & plant
- Environmental concerns
  - Effect operations and economics
- Institutional and contractual barriers




Source: BOR




Source: BOR



# Hydropower Plant Dispatch Displaces High Cost Thermal Generation and Minimize Ramping Levels




# Hydropower: Available Capacity/Capability & Uses



# Institution/Market Solutions

## ***Energy Imbalance Market (EIM)***

# Flexible Reserve Requirements Decrease as the Footprint Size Increases




- Greater diversity
- Wider and more refined grid visibility
- Expanded resource pool and larger dispatch footprint


# Small BA

— Wind Production    - - - Wind Owner EI    — Hourly Wind Production Change

Hourly Energy Imbalance (MW)




The Relative Level of Flexible Reserve Requirements Decrease as the Footprint Size Increases




CAISO – Large Footprint

# Flexible Reserve Requirements Increase as the Dispatch Time Interval Increases




# Lower Flexible Regulation Is Needed when the Grid Is Dispatched Every 5 Minutes - *Down Ramp Trend*






# CAISO EIM Growing List of Participating BAA

## CAISO EIM Timeline of 15-minute Scheduling and 5-minute Dispatch



## Ramping Sufficiency Test Schedule






# Comparison of Current Energy Imbalance Practices with the CAISO EIM

	<u>Without EIM</u>	<u>CAISO EIM</u>
<b>Footprint</b>	Single BA	Multiple BAs
<b>Balancing</b>	Individual BA and Sub-BAs	Optimize Participating Resources Dispatch
<b>Time Step</b>	Hourly	Hourly, 15 min, 5 min
<b>Settlement</b>	Financial or Energy Payback	Locational Marginal Price (LMP) & Neutrality Accounts

**Balancing occurs among EIM Entities**




An expanded set of pooled resources over a larger footprint lowers the cost of resolving energy imbalances

# Hour Ahead Schedule

Each Gen has a 100 MW Capacity

## A Larger Pool of Generation Resources Enable Markets to Reduce Production Costs




# Real-time Example: BA3 Outside of the EIM Market

**Energy Deviation: EI = -5**

**EI = +2**

**EI = -10**



**Total Cost = \$9,920**

# Real-time Example: BA3 Joins the EIM Market

**Energy Deviation: EI = -5**


**EI = +2**

**EI = -10**

Gen Cost

G1, \$10/MWh  
G2, \$20/MWh  
G3, \$30/MWh


**RT Higher Load**  
~~225~~ 230 MW



Gen Cost

G4, \$40/MWh  
G5, \$50/MWh


**RT Lower Load**  
~~100-98~~ MWh



Gen Cost

G6, \$60/MWh

**RT Higher Load**  
~~50~~ 60 MWh



Supply

G1, 100 MWh  
G2, 100 MWh  
G3, ~~75~~ 80 MWh  
**280 MWh**

**Demand**  
L1, 230 MWh  
HA Sale 50 MWh  
RT Sale 0 MWh  
**280 MWh**

Supply

G4, 100 MWh  
G5, 8 MWh  
HA Buy 50 MW  
**158 MWh**

**Demand**  
L2, ~~100-98~~ MWh  
HA Sale 50 MWh  
**148 MWh**

Supply

G6, 0 MWh  
DA Buy 50 MWh  
RT Buy 10 MWh  
**60 MWh**

**Demand**  
L3, ~~50~~ 60 MWh  
**60 MWh**

Production Cost

G1 \$1,000  
G2 \$2,000  
G3 \$2,400  
**\$5,400**

Production Cost

G4 \$4,000  
G5 \$400  
**\$4,400**

**Total Cost = \$9,800**

**w/o BA3 in EIM = \$9,920**



**Savings = \$120**

Production Cost

G6 \$0  
**\$0**

# The Long-term View

# How Do We “Best” Supply Future Demand Reliably



- Each technology has different technical and economic characteristics

102


- Maximum output
- Response & ramp time
- Start up time
- Minimum operating level
- Dispatchable (Y/N)
- Energy source(s) and efficiency profile
- Capital cost
- Fixed and variable operating and maintenance costs
- Rules, Priorities, Goals, and Objectives

**Operating Flexibility**

Integration of VRE influences dispatchable technology mix


**Economics Financial Viability**

# A Lot of Wind Capacity Is Needed to Meet Renewable Portfolio Standards (20% Energy)



**For wind and solar the capacity credit depends on the probability and amount of power that it provides during the time of peak load**


# Unit Production Levels Can Be Estimated Using a Load Duration Curve




Information such as unit ramping and unit starts/stops is lost




# The Firm Capacity Credit for Wind Can Be Based on a System Reliability Measure



# PV Solar Firm Capacity: WECC Rule of Thumb Values and Loss of Load Equivalent (LOLE) Estimate by NREL




# Wind Firm Capacity: WECC Rule of Thumb Values and Loss of Load Equivalent (LOLE) Estimate by NREL



# VRE Capacity Additions and Levelized Cost of Electricity (LCOE)


2016 Generation Capacity Additions (MW)




<http://www.renewableenergyworld.com/ugc/articles/2017/01/14/2016-us-solar-capacity-by-state-recap.html>

Plant type	Capacity factor (%)	Levelized capital cost	Levelized fixed O&M	Levelized variable O&M	Levelized transmission cost	Total system LCOE	Levelized tax credit <sup>2</sup>	Total LCOE including tax credit
<b>Dispatchable technologies</b>								
Coal with 30% CCS <sup>3</sup>	NB	NB	NB	NB	NB	NB	NA	NB
Coal with 90% CCS <sup>3</sup>	NB	NB	NB	NB	NB	NB	NA	NB
Conventional CC	87	13.0	1.5	32.8	1.0	48.3	NA	48.3
Advanced CC	87	15.5	1.3	30.3	1.1	48.1	NA	48.1
Advanced CC with CCS	NB	NB	NB	NB	NB	NB	NA	NB
Conventional CT	NB	NB	NB	NB	NB	NB	NA	NB
Advanced CT	30	22.7	2.6	51.3	2.9	79.5	NA	79.5
Advanced nuclear	90	67.0	12.9	9.3	0.9	90.1	NA	90.1
Geothermal	91	28.3	13.5	0.0	1.3	43.1	-2.8	40.3
Biomass	83	40.3	15.4	45.0	1.5	102.2	NA	102.2
<b>Non-dispatchable technologies</b>								
Wind, onshore	43	33.0	12.7	0.0	2.4	48.0	-11.1	37.0
Wind, offshore	45	102.6	20.0	0.0	2.0	124.6	-18.5	106.2
Solar PV <sup>4</sup>	33	48.2	7.5	0.0	3.3	59.1	-12.5	46.5
Solar thermal	NB	NB	NB	NB	NB	NB	NB	NB
Hydroelectric <sup>5</sup>	65	56.7	14.0	1.3	1.8	73.9	NA	73.9

# Each Thermal Generating Technology Has a Niche




# Combining Screening Curves with the Load Duration Curve Approximates the “Ideal” Capacity Mix




# The Capacity Credit Decreases with Higher Penetration of Wind Capacity in the System

- German utility E.ON: “The more wind power capacity is on the grid, the lower the percentage of traditional generation it can replace.”
  - Firm capacity from wind in 2007: about 7% of installed capacity
  - Firm capacity in 2020 is expected to drop to 4%.



# *If Possible Build Were Prices Are the Highest*






# VREs and Integrated Resource Planning (IRP)


- Produces a long-term resource strategy
- Integrates both supply and demand-side options
- Should consider risks and external impacts
- Evaluates cost-effectiveness and trade-offs among multiple objectives

## ➤ **Resource schedule**

- *Technology (type of gen)*
- *Reserve capacity*
- *Demand-side management*
- *System flexibility*




- When?
- What?
- How Much?



# IRP Analyses Typically Use Capacity Expansion Models

- Dynamic Programming (DP) capacity expansion models combine a production cost (dispatch) model with DP optimization
- Production cost models simulate power system operation and project costs for each expansion combination in each year of the study period
- The DP model finds the expansion path with the lowest net present value (NPV) of all **investments plus operating costs** that reliability serves demand



# Colorado Spring Utility IRP Process

## Project Plan

- Project Plan
- Assumptions
- Previous EIRP and Scope Planning

## First Public Mtg.

- Purpose: Introduction and Education**
- Project Planning and Stakeholder Engagement - Advisory Group begins meeting
- Data Collection and Analysis/Evaluation of Technologies

## Scenario Screening

- Evaluation:**
- Renewable and Traditional Resources
- Create Scenarios Based on Environmental Impacts, Risk, and Cost

## Second Public Mtg.

- Purpose: Evaluation and Reporting Back - Mid-point of EIRP Process**
- Share Preliminary Scenarios with Public
- Risk Analysis and Testing - Metrics and Assessment

## Technical Analysis

- Portfolio Analysis and Resource Selection**

## Third Public Mtg.

- Purpose: Share Results of Scenario and Portfolio Development**
- Obtain Input on Final Portfolio Selection - Prepare for Final Fourth Public Mtg.
- Advisory Group participates in Kepner-Tregoe, Risk and Cost Analyses

## Fourth Public Mtg.

- Purpose: Final Review of Recommended Portfolios/Obtain Input**
- Share Recommendations and Selection Criteria- Obtain Comments for UPAC and UB Review
- Outline Plan Update Process



## 2012 Electric Integrated Resource Plan



## IRP Considers


- Supply
- Demand
- Contractual Obligations
- Economics
- Demand Response
- Uncertainties (prices)
- Environment

# Colorado Springs Utility Scenario Analysis (No Simple Answer)

#	Scenario	Net Present Value-\$ million	Diff in NPV to Scenario 1 EV2020	Load Forecast	DSM Percent of sales by 2020	RPS Renewables Percent by 2020	Envir. Reg Adder \$/MWh	CO2 Adder \$/Ton	Gas and Electric Market Price	Coal Price
1	Energy Vision - Expected case	2,421.0	Base	Medium	10%	20%	1.5	3	Medium	Medium
2	Current Business Environment - Current Environmental Cost	2,255.6	-165.3	Medium	4%	10%	1.5	Zero	Medium	Medium
3	Current Business Environment - Mid Environmental Cost	2,621.8	200.8	Medium	4%	10%	7.5	3	Medium	Medium
4	Energy Vision - -20% carbon reduction	3,286.2	865.3	Medium	10%	20%	1.5	25	Medium	Medium
5	Low Load Growth	2,204.6	-216.4	Low	10%	20%	1.5	3	Medium	Medium
6	High Load Growth	2,670.1	249.1	High	10%	20%	1.5	3	Medium	Medium
7	High Environmental Regulation - High CO2 Cost	4,236.5	1,815.6	Medium	10%	30%	10.0	50	Medium	Medium
8	High GasPrice -High Electric Market Price	2,484.2	63.2	Medium	10%	20%	1.5	3	High	Medium
9	Low Gas Price -Low Electric Market Price	2,310.5	-110.5	Medium	10%	20%	1.5	3	Low	Medium
10	Mid DSM	2,447.0	26.0	Medium	6%	20%	1.5	3	Medium	Medium
11	No New Fossil Fuel	2,749.0	328.1	Medium	10%	30%	1.5	3	Medium	Medium
12	High RPS, Mid Environmental Cost	2,955.9	535.0	Medium	10%	30%	7.5	3	Medium	Medium
13	PPACG Sustainability	2,812.3	391.4	Medium	20% by 2030	50% by 2030	1.5	3	Medium	Medium
14	High DSM	2,334.5	-86.4	Medium	20%	20%	1.5	3	Medium	Medium
15	Low Load Growth - 10%RPS	2,165.9	-255.0	Low	10%	10%	1.5	3	Medium	Medium
16	Energy Vision - 10% RPS	2,374.5	-46.5	Medium	10%	10%	1.5	3	Medium	Medium
17	Energy Vision - 30% RPS	2,749.0	328.1	Medium	10%	30%	1.5	3	Medium	Medium
18	Current Business Environment - 6% DSM	2,248.8	-172.2	Medium	6%	10%	1.5	Zero	Medium	Medium
19	Energy Vision - Low Wind Integration Cost	2,411.4	-9.6	Medium	10%	20%	1.5	3	Medium	Medium
20	Current Business, No wind until RPS requires	2,296.6	-124.4	Medium	4%	10%	1.5	Zero	Medium	Medium
21	Current Business Environment - 10% DSM	2,251.5	-169.5	Medium	10%	10%	1.5	Zero	Medium	Medium
22	Current Business Environment - Low Gas Price	2,056.0	-365.0	Medium	4%	10%	1.5	Zero	Low	Medium
23	Energy Vision - Limited to 50MW of wind in 2013	2,465.8	44.8	Medium	10%	20%	1.5	3	Medium	Medium
24	Energy Vision - High Coal Price	2,919.4	498.4	Medium	10%	20%	1.5	3	Medium	High
25	Energy Vision - Low Coal Price	2,111.2	-309.8	Medium	10%	20%	1.5	3	Medium	Low
26	Current Business Environment - High Coal Price	2,790.6	369.6	Medium	4%	10%	1.5	Zero	Medium	High
27	Current Business Environment - Low Coal Price	1,919.6	-501.3	Medium	4%	10%	1.5	Zero	Medium	Low
28	Current Business Environment - High Gas Price	2,365.9	-55.1	Medium	4%	10%	1.5	Zero	High	Medium
29	Current Business Environment - High Load	2,513.5	92.6	High	4%	10%	1.5	Zero	Medium	Medium
30	Current Business Environment - Low Load	2,039.2	-381.8	Low	4%	10%	1.5	Zero	Medium	Medium
31	Energy Vision - zero CO2 adder	2,301.8	-119.1	Medium	10%	20%	1.5	Zero	Medium	Medium
32	Energy Vision - with no capacity for DSM	n.a.	n.a.	Medium	10%	20%	1.5	3	Medium	Medium
33	Energy Vision - Low Solar Costs	2,401.4	-19.6	Medium	10%	20%	1.5	3	Medium	Medium
34	Current Business Environment - No Pueblo Hydro	2,258.3	-162.7	Medium	4%	10%	1.5	Zero	Medium	Medium
35	Current Business Environment - No Geothermal	2,259.2	-161.8	Medium	4%	10%	1.5	Zero	Medium	Medium
36	Current Business Environment - No Pueblo Hydro - No Geo.	2,262.3	-158.7	Medium	4%	10%	1.5	Zero	Medium	Medium
37	Energy Vision, No Wind Until RPS Requires	2,528.5	107.5	Medium	10%	20%	1.5	3	Medium	Medium

# What is the “Best” Amount of VRE Capacity?

- Production variability
  - Level and frequency of production swings
  - Forecast error
- Correlation among variable resource
  - Volatility and predictability of **ALL** variable resources combined
- Production correlation with load
  - Production change during morning load up-ramp and evening load down-ramp
- Transmission system
  - Capability of the transmission systems to move power from production to load
- Flexibility of thermal/hydropower system
  - Dispatch interval
  - Rate that dispatchable units can respond to variable production and load changes
- Load flexibility or level of control
- Willingness to spend \$\$\$



***Thank you for your attention***


# ***Supplemental Slides***

## ***Resource Expansion Decisions***

# Vertically Integrated System

## Single Decision Maker Model

- In a traditional power system with **one** vertically-integrated utility company, all options (supply, demand, transmission, etc.) are evaluated based on cost and reliability (**total system situational awareness**)
  - Identify investment plan that reliably meets demand at the lowest net present value of all costs




---

# Competitive Market Uncertainty

## Numerous Decision Makers

- **Multiple** generation companies evaluate their options based on profitability and investment risk (**company perspective**)
- Identify investment with high profit potential and limited down-side risk




**Independent Financial Decisions May Result in a Path that Differs from a Least-Cost Economic System Expansion Plan**



# Uncertainty Analysis and Investment Decisions


- Future loads, fuel prices, etc. are uncertain
- In competitive markets multiple companies develop expectations and make **independent investment decisions** under uncertainty that affect LMPS



For each of these Futures there is a Unique Hourly LMP Profile

# Investment Decisions Are Influenced by Risk Preferences

*Mapping of Possible Financial Outcomes for Two Technology Choices*




# Survey of Integrated Resource Plans for Several Utilities in the Western US

Utility	Utility Type	Type of Generation added	When Added	Capacity Added (MW)
Public Service of CO	Investor Owned	Gas Turbines	2018 to 2022	1,211
		Combined Cycle	2023 to 2032	1,929
Public Service of NM	Investor Owned	Gas Turbines	2016 to 2033	736
		Solar PV	2015 to 2022	283
Rocky Mountain Power	Investor Owned	Combined Cycle	2014, 2024	645, 423
		Wind	2024	432
Arizona Public Service	Investor Owned	Natural gas (unspecified)	2019 to 2029	4,200
		Renewable (unspecified)	2019 to 2029	425
Tucson Elect. Power	Investor Owned	Natural gas (unspecified)	2015 to 2028	1,214
		Renewable (unspecified)	2014 to 2028	529
Nevada Power Company	Investor Owned	Combined Cycle	2018 to 2024	3,813
		Gas Turbines	2023 to 2032	2,043
		Solar PV	2016 to 2021	50
Sierra Pacific Power	Investor Owned	Gas Turbines	2023 to 2029	1,975
		Combined Cycle	2025	571
Platte River Power	Western Customer	Gas Turbines	2021	Unspecified
Colorado Springs Utilities	Western Customer	Gas Turbines	2029 to 2031	39
		Renewable (unspecified)	2018 to 2029	20
Tri-State G & T Assn.	Western Customer	Combined Cycle	2019 to 2026	1,176
		Renewable (unspecified)	2016 to 2027	350
Salt River Project	Western Customer	Natural gas (unspecified)	FY2018 +	projected 581 MW gap in 2017

# Coal Capacity Is Expected to Decline

## *Not as Flexible as Natural Gas Technologies*




# ***Supplemental Slides***

## ***LMPs and Financial Considerations***

# LMPs and Nuclear Plant Financial Impacts


## *Inflexible Base Load Operations*



Operating at a financial loss



# LMPs and Nuclear Plant Financial Impacts

## *Inflexible Base Load Operations - 1 Week*



# LMPs and Nuclear Plant Financial Impacts



## Inflexible Base Load Operations - 1 Week






# LMPs and Nuclear Plant Financial Impacts

## Inflexible Base Load Operations - 1 Month



# LMPs and Nuclear Plant Financial Impacts

## Moderate Operating Flexibility





**Operating at a financial loss**

\* Flexibility based on "Economic Ramifications of Nuclear Load-Following in an ERCOT-like Market under High Renewables Penetration and Energy Policies" (ANL paper funded by USDOE) 130


# LMPs and Nuclear Plant Financial Impacts

## Moderate Flexibility Case - 1 Week





***Supplemental Slides***  
***Forced and Scheduled Outages***

# Ideally, Units Are Dispatched Based on Production Cost




# Unit Outages Increase Costs

**This is why  
you need  
reserve  
capacity**




# Unavailable Capacity (GWh)



## Available Capacity






## “Typical” Year Outages



# Sample Hydropower Unit Outage Statistics (2000-2019)

## Outages Are Scheduled During Periods of Low Load/Energy Price



**Instead of operating all units at full capacity some units are dispatched at a lower so that when a unit is suddenly forced out of service the generation shortfall is immediately replaced by deploying the reserved capacity**



# Assess Contingency Reserve Requirements


All Possible of On/Off Combinations

Probability of Occurrence Sum to 1.0

U1	U2	U3	U4	U5	Probability
0	0	0	0	0	0.000114
0	0	0	0	1	0.000405
0	0	0	1	0	0.001072
0	0	0	1	1	0.003819
0	0	1	0	0	0.000447
0	0	1	0	1	0.001593
0	0	1	1	0	0.004216
0	0	1	1	1	0.015019
0	1	0	0	0	0.000937
0	1	0	0	1	0.003338
0	1	0	1	0	0.008834
0	1	0	1	1	0.031472
0	1	1	0	0	0.003685
0	1	1	0	1	0.013126
0	1	1	1	0	0.034740
0	1	1	1	1	0.123760
1	0	0	0	0	0.000347
1	0	0	0	1	0.001238
1	0	0	1	0	0.003276
1	0	0	1	1	0.011670
1	0	1	0	0	0.001366
1	0	1	0	1	0.004867
1	0	1	1	0	0.012881
1	0	1	1	1	0.045890
1	1	0	0	0	0.002863
1	1	0	0	1	0.010199
1	1	0	1	0	0.026993
1	1	0	1	1	0.096163
1	1	1	0	0	0.011258
1	1	1	0	1	0.040107
1	1	1	1	0	0.106149
1	1	1	1	1	0.378156

		U1	U2	U3	U4	U5
<b>Capacity (MW)</b>		<b>400</b>	<b>300</b>	<b>75</b>	<b>200</b>	<b>90</b>
Outage Cause A	Occurrences/year	2	1	1	4	6
	Outage Length (Days)	21	17	14	8	10
Outage Cause B	Occurrences/year	4	2.5	12	1	5
	Outage Length (Days)	12	9	5	3	4


	U1	U2	U3	U4	U5
<b>Cause A Days Out</b>	42	17	14	32	60
<b>Cause B Days Out</b>	48	22.5	60	3	20
<b>Total Days Out</b>	90	39.5	74	35	80
<b>Time Out of Service (frac)</b>	0.25	0.11	0.20	0.10	0.22




**Folding a piece of paper 42 times reaches the moon – the curse of dimensionality**

# Representing Random Forced Outages in Real Time Models

Use a forced outage time series that has a distribution that is similar to a target profile



The time series of chronological forced outages have an impact of total production cost



Target Outages					Avail Cap Hrs	
Cap (MW)	Cause A	Cause B	Total	% Outage	(GWh/yr)	
U1	400	42	48	90	25	2,640
U2	300	17	48	65	18	2,160
U3	75	14	48	62	17	545
U4	200	32	48	80	22	1,368
U5	90	60	48	108	30	555
<b>Total</b>	<b>1065</b>	<b>165</b>	<b>240</b>	<b>405</b>		<b>7,269</b>

Random Draws					Difference from Target (%)		Avail Cap Hrs	
	Cause A	Cause B	Total	% Outage	(GWh/yr)			
U1	63	47	110	30	5	2,448		
U2	27	18	45	12	-5	2,304		
U3	14	48	62	17	0	545		
U4	40	3	43	12	-10	1,546		
U5	58	48	106	29	-1	559		
<b>Total</b>	<b>202</b>	<b>164</b>	<b>366</b>			<b>7,402</b>		
<b>% of Target</b>	<b>122</b>	<b>68</b>	<b>90</b>					

		U1	U2	U3	U4	U5
Outage Cause A	Occurrences/year	2	1	1	4	6
	Outage Length (Days)	21	17	14	8	10
Outage Cause B	Occurrences/year	4	2.5	12	1	5
	Outage Length (Days)	12	9	5	3	4


134 Difference from Target (GWh)

**When an outage occurs the supply stack becomes smaller increasing LMP**

# ***Supplemental Slides***

## ***Pumped Storage Hydro***


# Optimal Operation of a Hypothetical Adjustable Speed PSH Unit Located in California



***Supplemental Slides***  
***Reservoir Inflow Forecast Error***


# Long-term Scheduling of Limited Energy Resources

*Perfect Foresight*



# Typical Scheduling and Dispatch Sequence

*Schedulers and Operators React to Changing Projections and Evolving Conditions*




# ***Supplemental Slides***

## ***Hydropower Dispatch Decisions Under Uncertainty***





# Hour Ahead Schedule Based on Projected LMPs

## *Hydropower Resource with a Limited Daily Water Release Volume*





# Models with "Perfect" Foresight Are Often Unrealistic

Example: DA & RT prices are the same except for the hour 12 RT spike



# Model Runs and Sequencing that Mimic the Decision Making Process

- Each model run simulates a single day
- Run HA (hourly), then DA (hourly), then RT (5-min)
- Rules represented by a combination of hard and soft constraints dictate how schedules and operations can deviate from previous schedules/operations over time
- For each day
  - DA model is run one time informing the HA & RT
  - HA is run 24 times using updated forecasts each hour
  - RT is run 24 times using updated forecast each hour



The user has knobs/levers that can be adjusted to change the shape of the forecast accuracy curve from no foresight to perfect foresight

The RT curve can differ from the HA curve

**Run Sequence** (Green Highlight: Simulated history - held fixed) (Yellow Highlight: Projected future – updated by model)

<b>DA<sub>1</sub></b>	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
<b>HA<sub>1</sub></b>	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
<b>RT<sub>1</sub></b>	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
<b>HA<sub>2</sub></b>	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
<b>RT<sub>2</sub></b>	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
<b>HA<sub>3</sub></b>	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
<b>RT<sub>3</sub></b>	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
<b>HA<sub>4</sub></b>	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
<b>RT<sub>4</sub></b>	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24



*Flexible Operation Period* | *Water Release Adjustment Period*

<b>HA<sub>24</sub></b>	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
<b>RT<sub>24</sub></b>	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
<b>DA<sub>2</sub></b>	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24